

OFFICE OF THE CHIEF MEDICAL OFFICE, HAPUR

Ref. No. DSO/IDSP/2026/ 4306

Date:- 16.05.2026

Bacteriology Water Analysis

SAMPLE IDENTIFICATION	
Sample site	THE HERITAGE WORLD SCHOOL PLOT NO 1458 DHAULANA, HAPUR
Source (Tap/R.O)	R.O
Date & time of collection	14/05/2026
Date & time of first analysis	15/05/2026
Date & time of reporting	16/05/2026
Sample volume inoculated	100ml
No.of tubes inoculated	1(50ml)+5(10ml)=6
PRESUMPTIVE TEST	
No. of positive tubes in presumptive test at 37°C after 24 hours	ZERO
At 48 hours	ZERO
Most probable number (MPN) /100ml of water Total coliforms	0/100ml

INTERPRETATION-

Water Bacteriology	<u>EXCELLENT</u>
--------------------	------------------

Classification of quality drinking water supply	
Quality of drinking water supply	Coliform count /100ml
➤ Excellent	➤ 0
➤ Satisfactory	➤ 1-3
➤ Intermediate	➤ 4-9
➤ Unsatisfactory	➤ ≥10

Comments:

Most probable number (MPN) /100ml of water reflect 0/100 ml and the interpretation is excellent that water is free from Coliforms Organism.

Recommendation:

Given water safe for drinking purpose.

- This Satisfactory report/result is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.
- **Validity upto one year.**


Microbiologist/NMS
IPHL Lab, DCH
Hapur


(Dr. Dinesh Bharti)
District Surveillance Officer
District Hapur

जिला सर्विलेन्स अधिकारी,
जनकपुर हापुर

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 4306

Date:- 16.05.2026

It is certified that an inspection team headed by Mr. Tanuj Sharma, Microbiologist/NMS from IDSP UNIT, Hapur inspected the **THE HERITAGE WORLD SCHOOL PLOT NO 1458 DHAULANA, HAPUR** on 14-05-2026 and on the basis of water Test Report Bearing no. DSO/IDSP/2026/4306 dt 16-05-2026 of IDSP, Hapur certified that the **THE HERITAGE WORLD SCHOOL PLOT NO 1458 DHAULANA, HAPUR** has safe water facilities for the students and member of staff of the institution school also maintaining the hygienic sanitation conditions in the school building & campus as per norms prescribed by state Government. This certificate is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.

➤ **Validity up to one year**


(Dr. Dinesh Bharti)

District Surveillance Officer

District Hapur

जिला सविलान्स अधिकारी,
जनपद हापुड

To,

THE HERITAGE WORLD SCHOOL,

PLOT NO 1458 DHAULANA, HAPUR